

PART 01100 - WATER SUPPLY SYSTEMS

TABLE OF CONTENTS

Section 01120 - Irrigation Systems	1
01120.00 Scope	1
01120.01 Qualifications	1
01120.10 General.....	1
01120.11 Pipe, Tubing, and Fittings.....	1
01120.12 Automatic Controllers	2
01120.13 Quick-Coupling Equipment.....	3
01120.14 Hose Bibs	4
01120.15 Cross-Connection Control Devices.....	4
01120.16 Water Meter.....	4
01120.17 Valves.....	4
01120.18 Valve Boxes and Protective Sleeves.....	5
01120.19 Electrical Wire and Splices	5
01120.20 Communication Cable	5
01120.21 Detectable Wire and Marking Tape	5
01120.40 General.....	6
01120.41 Layout of Irrigation System.....	6
01120.42 Excavation.....	6
01120.43 Piping	7
01120.44 Pipe Jointing.....	7
01120.45 Installation	8
01120.46 Low Voltage Electrical Installation	8
01120.47 Flushing and Testing	9
01120.48 Adjusting System.....	9
01120.49 Backfill	10
01120.60 System Operation.....	10
01120.61 Drip Line Warranty.....	10
01120.70 As-Built Plans and System Orientation.....	10
01120.80 Measurement.....	11
01120.90 Payment	11
Section 01140 - Potable Water Pipe and Fittings.....	12
01140.00 Scope	12
01140.10 Materials.....	12
01140.11 Handling Pipe and Fittings.....	12
01140.12 Cutting Pipe.....	12
01140.40 Trench Work	13
01140.41 Laying Pipe.....	13
01140.42 Jointing Pipe.....	14
01140.43 Polyethylene Encasement	14
01140.44 Thrust Restraint.....	14
01140.45 Marking Tape and Wire	15
01140.46 Blowoff Assemblies	15
01140.47 Connections to Existing Mains.....	15
01140.48 Maintaining Service	16
01140.49 Backfilling	16
01140.50 Filling and Flushing.....	16
01140.51 Hydrostatic Testing.....	16
01140.52 Disinfecting.....	18
01140.80 Measurement.....	19
01140.90 Payment	20

Section 01150 - Potable Water Valves	22
01150.00 Scope	22
01150.10 Materials.....	22
01150.11 Handling	22
01150.12 Connecting Ends	22
01150.40 General.....	22
01150.41 Combination Air Release/Air Vacuum Valves.....	23
01150.50 Field Testing.....	23
01150.51 Hydrostatic Testing.....	23
01150.52 Disinfecting.....	23
01150.80 Measurement.....	23
01150.90 Payment	23
Section 01160 - Hydrants and Appurtenances	24
01160.00 Scope	24
01160.10 Materials.....	24
01160.11 Handling of Hydrants	24
01160.40 Setting Hydrants	24
01160.41 Hydrant Laterals	24
01160.42 Hydrant Restraints.....	24
01160.43 Auxiliary Gate Valves and Valve Boxes.....	25
01160.44 Hydrant Guard Posts	25
01160.45 Resetting Existing Hydrants	25
01160.46 Moving Existing Hydrants	25
01160.47 Reconnecting Existing Hydrants.....	25
01160.48 Hydrant Extensions	25
01160.50 General.....	25
01160.51 Hydrostatic Testing.....	25
01160.52 Disinfecting.....	25
01160.80 Measurement.....	25
01160.90 Payment	26
Section 01170 - Potable Water Service Connections, 2 Inch and Smaller.....	27
01170.00 Scope	27
01170.10 Materials.....	27
01170.40 General.....	27
01170.41 Reconnecting Existing Services	27
01170.42 Sampling Stations.....	28
01170.50 Flushing and Disinfecting	28
01170.51 Hydrostatic Testing.....	28
01170.80 Measurement.....	28
01170.90 Payment	28

Section 01120 - Irrigation Systems

Description

01120.00 Scope - This work consists of installing irrigation systems and associated equipment at locations shown or specified and as directed.

01120.01 Qualifications - In order to install certain kinds of equipment or systems, manufacturer's certifications may be required, if described in the Special Provisions.

Materials

01120.10 General - Furnish only commercial quality materials and equipment. All items proposed for use will be subject to testing to ensure compliance with the Specifications. Provide materials of the same function that are of the same type and the same manufacturer.

Submit a list of proposed materials for approval as soon as practicable after Award and before arranging for procurement of any materials, especially those materials or products not shown or specified. If any initially proposed materials are not approved, submit substitutes for approval. Any materials installed without approval will be subject to removal and replacement with acceptable material at no additional cost to the Agency.

Materials may be designated by trade name or by manufacturer's catalogue information as shown or specified. The use of a substitute material may be allowed if a written request for substitution and proof of equivalent quality and suitability are furnished. Make any request for substitution with ample time for approval without delaying the work.

When alternate equipment, such as sprinkler heads, is proposed for use with hydraulic characteristics differing from that originally shown, the following will be required:

- A redrafted, legible plan that shows the redesigned layout, location, or sizes of every affected system element as required for proper operation as originally designed. Furnish a plan showing every relevant system element, site feature, and plan element that was shown on the original plan. A plan made by marking up the original plan will not be accepted.
- A hydraulic calculation table for the alternate equipment. At a minimum, show a complete calculation for one average sprinkler zone (section) and a complete calculation for the "worst case" sprinkler zone (i.e., the section that is farthest from the point of connection (P.O.C.), is the largest, or otherwise presents the most challenging hydraulics). Starting from the P.O.C., show the calculation with a step-down method with flow and loss at each piece of equipment and length of pipe run between equipment. Show the new total water required for each zone and the total for all zones to ensure that maximums for meter size, pipe sizes, and watering times will not be exceeded.
- Where any controller run-time change will be required, submit a separate page showing the total timing per controller required for each section, to show that timing changes will still allow all zones to be run within a reasonable time period.
- A cost page showing the Contractor's actual discount cost from the suppliers, comparing the original plan costs versus the proposed equipment costs for each type of item, such as pipe by size, where there is a change required. Show the line total of each type of item and the grand total for the proposed change.

01120.11 Pipe, Tubing, and Fittings - Furnish galvanized iron or steel, PVC, or polyethylene pipe as shown or specified that meets the following requirements:

(a) Galvanized Pipe and Fittings - Furnish pipe of standard weight, hot-dip galvanized iron or steel, standard threaded, coupled, and that meets the requirements of ASTM A 53. Non-standard threaded fittings will be rejected.

(b) Polyvinyl Chloride Pipe and Fittings - Furnish PVC pipe and fittings of PVC compound Type 1, Grade 1, conforming to ASTM D 2241 and certified approved by the National Sanitation Foundation. Provide pipe and fittings free from defects caused by poor materials, low quality of work, or rough handling. Dimensional and quick burst tests of pipe and fittings may be required after arrival at the job site before materials will be accepted.

Furnish pipe and fittings as follows:

Used for	Class or Schedule
Main and lateral lines	Class 200 or Schedule 40 PVC
Irrigation sleeves	Schedule 40 PVC
Caps.....	Schedule 80 PVC
Direct bury pipe, not in sleeves, placed under road beds or other paved areas	Schedule 40 PVC

Unless otherwise specified, furnish entire Project with one pipe class or schedule type.

Furnish PVC threaded pipe of PVC 1120, schedule 80 material conforming to ASTM D 1785.

Provide PVC solvent-weld pipe of PVC 1120 materials having a 200 psi minimum pressure rating with SDR 21 walls that conform to ASTM D 2241.

Furnish PVC pipe fittings conforming to ASTM D 2466, Type I, Grades 1 or 2.

Pipe may be belled on one end with the dimensions of the tapered bell conforming to ASTM D 2672.

Install PVC pipe with walls heavier than SDR 21 when shown or specified.

(c) Non-Potable Colored Coded Pipe - Wherever non-potable, reclaimed or reuse water is used, furnish PVC pipe that is tinted purple and imprinted with the warning "Caution: Reclaimed Water - Do Not Drink". Provide pipe meeting the same AWWA and ASTM specifications as the potable water pipe sizes on which they are based.

(d) Polyethylene Pipe - Furnish polyethylene pipe of Class 80, SDR 15, medium density, meeting the requirements of ASTM D 2239, conforming to U.S. Commercial Standard CS-255, and approved by the National Sanitation Foundation (NSF).

(1) Micro Tubing and Fittings - Where drip emitters are not required, furnish a blank type and provide any connections necessary. Provide tubing consisting of nominal-sized linear, low-density, minimum 1/4 inch outside diameter (OD) polyethylene.

(2) Low Volume (Drip) Tubing - Furnish drip tubing manufactured from specially formulated, chemical-resistant, low to medium density, virgin polyethylene or polybutylene which is selected for excellent weatherability and stress cracking resistance, and is designed specifically for use in drip irrigation systems. Provide drip tubing having a minimum wall thickness of 0.044 inch.

01120.12 Automatic Controllers - Provide Underwriter's Laboratories (UL) approved controllers as shown or specified. Furnish each outdoor controller with either a pedestal or wall mount brackets

when appropriate. Provide and install the controller in a weatherproof and vandal-proof cabinet of corrosion-resistant metal. Furnish the controller housing or cabinet with hasp and lock or locking device. Provide locks or locking devices that are master-keyed and include three sets of keys for the locks. If the irrigation system serves both lawns and planting beds, furnish a controller that has a dual programming capability. Provide controllers that are compatible with and capable of operating the irrigation system as constructed.

The following are definitions of some controller-associated equipment:

Rain Sensor - A sensor able to interrupt the power from the irrigation controller to the valves when the rainfall exceeds a pre-selected amount. Furnish rain sensors that are compatible with the system controller and are fully adjustable.

Soil Moisture Sensor - A sensor that interrupts programmed irrigation cycles until the soil moisture reaches a predetermined condition at the sensor's probe location.

Central Controller - A computer system programmable to receive data from and provide commands to multiple irrigation systems remotely located from the central system location.

Satellite Controller - A satellite controller similar to a normal stand-alone controller and able to operate as one, but designed to be operated by a central controller located off-site.

Flow Sensor - The hardware located in a pipeline that senses water flow and sends resulting data by electronic pulses to the pulse output transmitter.

Pulse Output Transmitter - A device that reads electronic pulses from the flow sensor and sends data to the pulse-decoding device.

Pulse Decoder - A microprocessor-based device designed to read electrical pulses originating at the flow sensor (or other type of monitoring device) and send the data to a central control system for analysis and action. When reading water flow data, the pulse decoder may also be referred to as a flow monitor.

Weather Station - A field station that collects and stores various weather data for access and use by a central control system in modifying an irrigation program for weather conditions. Typical data collected over a time period are wind speed, wind direction, relative humidity, rainfall, solar radiation and air temperature.

01120.13 Quick-Coupling Equipment - Furnish quick coupling equipment with a body of cast leaded semi-red brass alloy No. C84400 conforming to ASTM B 584, and a service rating not less than 125 psi for non-shock cold water. Provide couplers having standard male pipe threads at the top and standard female pipe threads at the base. Ensure that the valve is designed to open only upon inserting a coupler key and close completely after removing the key, with absolutely no leakage of water between the coupler and valve body. Provide valve bodies to receive couplers that are designed with double worm slots to allow smooth opening and closing action with a minimum of effort. Ensure that slots notched at the base will hold the coupler firmly in the open position. Furnish couplers of one piece construction with steel reinforced side handles attached, a locking top and of the same material as the valve body. The coupler shall have stainless steel double guide lugs to fit the worm slots. Furnish two couplers and two hose swivels for operation of the valves, and two keys for the locking caps if quick-coupling valves are required. For non-potable water systems, furnish a color-coded, purple tinted cap that bears the printed warning "Caution: Reclaimed Water - Do Not Drink".

01120.14 Hose Bibs - Furnish bronze or brass hose bibs, with angle-type thread to accommodate a 3/4 inch hose connection, and with a key- operated design that prevents operation by wrench or pliers.

01120.15 Cross-Connection Control Devices - Cross-connection control devices will be shown on the plans. Furnish and install cross-connection control devices meeting the requirements of the Oregon Health Division and the local water authority.

01120.16 Water Meter - Water meter procurement, installation, and associated costs will be the responsibility of the Agency. Be responsible for coordinating water meter needs in a timely fashion with the Agency.

01120.17 Valves:

(a) Gate Valves - Furnish gate valves of heavy-duty bronze conforming to the requirements of ASTM B 62. Provide valves of the same size as the pipes on which they are placed and install with union or flange connections. Service rating (for non-shock cold water) shall be 150 psi. Valves shall be of the double disk, taper seat type, with rising stem, union bonnet and hand wheel or suitable cross wheel for standard key operation. The valves shall have the manufacturer's name, type of valve, and size clearly cast on them.

(b) Drain Valves - Furnish bronze or brass drain valves, 1 inch or 3/4 inch in size, manual angle globe type, with rising stem, hex brass union, removable bonnet and stem, and adjustable packing gland. Ensure that valves are designed for underground installation with a suitable cross wheel operable with a standard key. The valves shall have a service rating of not less than 150 psi non-shock cold water. Furnish three standard operating keys.

(c) Check Valves - Furnish heavy duty bronze or steel check valves which function by means of a hinged disc suspended from the body, and which is able to close of its own weight. Furnish valves that are of the same size as the pipes on which they are placed, unless otherwise specified, and with union or flanged connections. Provide valves that are rated for non-shock cold water service of not less than 150 psi. The valves shall have the manufacturer's name, valve type, and size cast on them.

(d) Pressure-Reducing Valves - Furnish pressure-reducing valves with a minimum of 150 psi working pressure and an adjustable outlet range of 20 psi to 70 psi, rated for non-shock cold water service up to 175 psi. The valves shall be factory set as shown or specified.

(e) Isolation Valve - Furnish isolation valves as shown on the plans or Special Provisions. If no isolation valve is shown, furnish ball valves as shown below.

(f) Ball Valves - Furnish bronzed-bodied ball valves conforming to ASTM B 62 and with a hard, chrome plated ball conforming to ASTM B 124. The valve shall be non-shock cold water service-rated at not less than 400 psi. Plastic valves will not be accepted.

(g) Air Relief Valve - The air relief valve automatically relieves air pressure to break an air vacuum in the pipe section where it is located. Install air relief valves at the exact high point of each pipe section where relief is needed. (Note: air relief valves are not associated with backflow prevention).

(h) Control Valves:

(1) Manual Control Valves - Furnish manual valves of bronze or brass, angle type, with hex brass union, and with a service rating not less than 150 psi non-shock cold water. Provide valves for underground installation designed with a cross wheel suitable for operation with a

standard key. Furnish three suitable operating keys per irrigation system. Furnish valves that have removable bonnet and stem assembly, with adjustable packing gland housing for the long acme-threaded stem to ensure full opening and closing. Provide valves with discs that are full floating with replaceable seat washers.

(2) Automatic Control Valves - Furnish automatic control valves of a normally closed design, operated by an electric solenoid of the required rating, but not more than 6.5 W and operating on 24 V AC power. Ensure that solenoids directly attached to the valve bonnets or bodies have completely internal control parts. Provide bodies that are not less than 150 psi if brass or bronze and not less than 125 psi if plastic, with a manual control bleed cock to operate the valve without electric current. Ensure that the closing speed is not less than 5 seconds and the opening speed is not less than 3 seconds. Both shall be at a constant rate of opening and closing so the water flow is completely stopped when the valve is either manually or electrically closed. Provide valves having manual shutoff stems with cross handles that will adjust the valve from fully closed to wide open with the valve automatically operable in the adjusted position.

(3) Automatic Control Valves with Pressure Regulator - Furnish valves of the same manufacture as the automatic control valves, capable of reducing the inlet pressure to a constant lower pressure regardless of supply fluctuations, and which are fully adjustable.

01120.18 Valve Boxes and Protective Sleeves - Provide automatic control valves, flow control valves, pressure reducing valves, backflow preventers, filters and other serviceable fixtures with valve boxes that are extendable to obtain the depth required. Furnish boxes constructed of thermoplastic, with locking lids, green in color, and of the type shown or specified. Include a protective sleeve and cap with all manual drain valves and manual control valves.

01120.19 Electrical Wire and Splices - Unless otherwise specified, furnish electrical wiring used as a hot wire for each zone between the automatic controller and automatic valves of copper, minimum size AWG No. 14, and red in color. Furnish common wire that is a minimum AWG No.12 and white in color. Furnish type USE that is chemically cross-linked polyethylene or thermoplastic. Furnish Type UF that is color-coded or marked with number identification.

Make low voltage splices with one of the following:

- A waterproof sealed wire connector system that is sealed from moisture, securely joins two or more conductors both mechanically and electrically, is rated for direct burial according to the manufacturer's recommendations, and conforms to UL 486D for direct burial applications. Wrapping a splice in tape is not an acceptable method of waterproofing. Obtain approval of the sealed wire connector system from the Engineer before installation.
- Heat-shrinkable insulating tubing manufactured for use in irrigation electrical systems. Furnish heat-shrink tubing of a mastic-lined, heavy-wall, polyolefin cable sleeve.

Provide and install an extra wire with all wiring runs that is the same gauge, but of a different color than the hot wire and common wire. The extra wire will be reserved for future use or modifications to the system.

01120.20 Communication Cable - Furnish communication wire in central satellite control systems that is 18 gauge polyethylene (PE) 89, minimum 6 pair, or approved equal. Provide sufficient pairs to connect all decoding, sensing and monitoring devices to the Central Control Unit.

01120.21 Detectable Wire and Marking Tape - Provide a detectable wire using continuous No. 14 gauge, single strand locator wire that is blue in color. Provide marking tape consisting of inert polyethylene plastic that is impervious to all known alkalis, acids, chemical reagents, and solvents likely to be encountered in the soil. Furnish color-coded tape with the type of line buried

below and the word "Caution" imprinted continuously over its entire length in permanent black ink. Provide tape of the width recommended by the manufacturer for the depth of installation used.

Construction

01120.40 General - The irrigation plans are a schematic design and may require adjustment. Do not install the sprinkler system as shown if it is evident that obstructions, grade differences, or differences in area dimensions create conditions different than anticipated in the design. Bring all such obstructions or differences to the attention of the Engineer. In the event this notification is not performed before construction begins on a part of the system where discrepancies exist, any revisions necessary to make the system operate as designed will be the Contractor's responsibility.

(a) Plumbing - Install all parts of the irrigation system according to the Oregon Plumbing Code and State and local laws. Make water service connections as shown and specified. Conform to the requirements of the jurisdictional water authority. Ensure that water velocities in PVC pipe do not exceed 5 feet per second, unless approved in writing by the Agency. Bring any velocities exceeding 5 feet per second created by pipe sizes shown on the plans to the attention of the Agency before beginning construction. Correct excess velocities existing after construction, or caused by changes from the plans, at no additional cost to the Agency, unless a written agreement has been made authorizing otherwise.

(1) Double Check Valve Assembly - Install, inspect, and test the double check valve assembly (DCVA) according to applicable regulations of the Oregon Health Division and the local water authority. Furnish test records on forms approved by the Oregon Health Division. Furnish forms filled out by a State-licensed Backflow Device Tester documenting that the DCVA is in good operating condition before any flushing and testing of downstream water lines. During the life of the Contract, test the DCVA annually, or more often if successive inspections indicate repeated failure. Repair or replace the DCVA whenever it is found to be defective.

(2) Reduced-Pressure Backflow Device - Install, inspect, and test the reduced-pressure backflow device (RPBD) according to the applicable portions of the Oregon Plumbing Code and applicable regulations of the Oregon Health Division and the local water authority. Apply the same specific testing requirements as stated for the DCVA above.

(b) Electrical Service - Install electrical service according to 00960.49, the National Electrical Code, and all State and local laws. Power sources will be as shown or as directed. Be responsible for coordination and installation of electrical service. Furnish and install meter bases at the power source conforming to the requirements of the power supplier. Give the power supplier's representative notice before making any installation. Provide a separate, dedicated circuit for the controller.

01120.41 Layout of Irrigation System - Stake the irrigation system, following the schematic design on the plans, before construction begins. With prior approval, make alterations and changes in the layout to conform to ground conditions and to obtain adequate coverage of water. Comply with the requirements of 00150.50.

01120.42 Excavation - Excavate trenches no wider than necessary to lay the pipe or install the equipment. Keep the top 6 inches of topsoil, if applicable, separate from subsoil and replace this topsoil as the top layer when backfilling. Provide smooth trench bottoms of sand or other material, free from rocks and unsuitable material. Excavate trenches in rock or other unsuitable material at least 6 inches below the required depth and backfill with sand or other suitable material free from rocks.

Exercise care when excavating near existing trees. Where roots are 2 inches and greater in diameter, except in the direct path of the pipe, hand excavate and tunnel the pipe trench. When large roots are exposed, wrap them with heavy burlap for protection and to prevent excessive drying. When digging trenches by machine adjacent to trees having roots 2 inches and less in diameter, hand trim the sides of the trench, making a clean cut of the roots. Treat all cut and trimmed roots 1/2 inch or larger in diameter with an approved tree wound dressing. Backfill trenches having exposed tree roots within 24 hours unless protected by continuously moist burlap or canvas.

Place detectable marking tape and tracer wire in the trench directly above, parallel to, and along the entire length of all nonmetallic water pipes and all nonmetallic and aluminum conduits installed under existing or planned pavement. Use tape widths recommended by the manufacturer for the burial depth.

Pipe installation using a "pipe puller" may be approved if there is adequate topsoil depth and the topsoil is free of rock. Obtain the Engineer's approval before using a pipe puller. Include any resultant changes in material or design with the request for use of this method.

If unforeseen bedrock is encountered during excavation that prevents the pipe from being buried at the specified depth, immediately bring it to the attention of the Engineer.

01120.43 Piping - Backfill all pipe between the top of the pipe and finished grade with a minimum of 18 inches of fill according to 01120.49. Where possible, place mains and laterals or section piping in the same trench. Separate all pipes by at least 2 inches. Place all pipe lines a minimum of 3 feet from the edge of concrete sidewalks, curbs, guardrail, fences, traffic barriers or walls unless otherwise approved.

Place marking tape and tracer wire above all pressurized mainline, according to the manufacturer's instructions.

Place all live mains to be constructed under existing pavement in sleeves jacked under the pavement, unless otherwise shown. Place all PVC pipe installed under pavement in pipe sleeves of Schedule 40 PVC, unless steel sleeving is shown or specified. Furnish pipe caps of Schedule 80 PVC. Install sleeves 2 feet below subgrade when passing under roadways. Extend sleeves 2 feet beyond the edge of gravel, edge of sidewalk or back of curbs. Mark sleeves with a 2 feet piece of No. 4 rebar driven flush with the ground or other adjacent surface. Place PVC caps over both ends of sleeves but do not glue. Solvent-weld sleeve sections. Pipe bedding and backfill shall conform to Section 00405. Extend the sleeve a minimum of 12 inches beyond the edge of pavement. Perform all jacking operations according to an approved jacking plan. If obstacles are encountered during required jacking, notify the Engineer, who may authorize corrective measures according to 00140.60. Provide for complete drainage of all pipe lines with manual drain valves installed at section low points. Drain valves may not be shown on the plans.

01120.44 Pipe Jointing:

(a) General - During construction, plug or cap pipe ends to prevent entry of dirt, rocks and other debris.

(b) Galvanized Steel Pipe - Ensure that galvanized steel pipe has clean cut, well fitted standard pipe threads. Ream all pipe to its full diameter and remove burrs before assembly. Construct threaded joints using either a non-hardening, non-seizing multipurpose sealant, teflon tape, or paste as recommended by the pipe manufacturer. Make all threaded joints tight with wrenches, without using handle extensions. Clean and remake joints that leak with new material. Use of caulking or thread cement to make joints tight will not be allowed.

(c) PVC Pipe - Handle and install PVC pipe, couplings and fittings according to the manufacturer's recommendations. Chamfer the outside of the PVC pipe to a minimum of 1/16 inch at approximately 22 degrees. Join pipe and fittings by solvent welding. Use only solvents that penetrate the surface of both pipe and fitting with a result of complete fusion at the joint. Use solvent and cement only as recommended by the pipe manufacturer. On plastic to metal connections, work the metal connection first. Use a non-hardening compound on threaded connections. Thread connections between metal and plastic using only female threaded PVC adapters with threaded Schedule 80 PVC nipples.

(d) Polyethylene Pipe - Install polyethylene pipe and fittings according to the manufacturer's recommendations. Cut the ends of the polyethylene pipe square and insert the fitting to its full depth. Use stainless steel clamps for insert fittings.

01120.45 Installation:

(a) Sprinkler Heads - Position turf heads and other pop-up heads between 1/2 inch and 1 inch above finish grade, measured from the top of the sprinkler. Place sprinklers as close as practical to walks, curbs, pavement and lawn edges, but leave enough space to allow height adjustment. Do not place heads on risers in areas with any potential for pedestrian traffic, unless otherwise shown. Use swing riser assemblies that allow positioning for correct sprinkler height.

(b) Drip Emitters - Install emitters directly above the root mass of the plant being watered, according to the plans or the manufacturer's recommendations.

(c) Low Volume Drip Tubing - Install drip irrigation tubing as shown and the manufacturer's recommendations.

(d) Controllers - Install controllers according to the manufacturer's recommendations and as shown. Receive approval of the location before installing. Since the controller will need to be accessed frequently, install it at a height, position, and location that allow ease of access.

(e) Valve Boxes and Quick Couplers - Position the tops of valve boxes, capped sleeves, and quick coupler valves between 1/2 inch and 1 inch above finish grade or mulch.

(f) Valves - Install valves so that access for maintenance is maintained.

(g) Central Control Equipment - If shown or specified, install the following equipment according to the manufacturer's recommendations:

- Rain sensors
- Soil moisture sensors
- Flow meters
- Central control system with satellite controllers
- Weather stations

01120.46 Low Voltage Electrical Installation - Use direct burial wiring between the automatic controller and automatic valves. Install waterproof splices according to the manufacturer's recommendations. The wiring may share a common neutral. When more than one automatic controller is required, provide a separate common neutral for each controller and the automatic valves it controls. Run separate control conductors from the automatic controller to each valve. Provide and install an extra wire according to 01120.40.

Install wire adjacent to or beneath the irrigation pipe. Use plastic tape or nylon tie-wraps to bundle wires together at 10 foot intervals. Snake the wire from side to side in the trench to provide slack in

the wire run. When it is necessary to run wire separate from the irrigation pipe, bundle and place the wire under detectable marking tape. Splices will be allowed only at junction boxes, valve boxes, pole bases, or control equipment. Leave a minimum of 2 feet of excess conductor at all splices, terminals and control valves to facilitate inspection and future splicing.

01120.47 Flushing and Testing:

(a) General - Provide gauges used in the testing of water pressures that are certified correct by an independent testing laboratory immediately before use on the Project. Retest gauges when directed. Test automatic controllers by actual operation for a period of 2 weeks under normal operating conditions. If adjustments are required, adjust according to the manufacturer's direction and test until operation is accepted as satisfactory.

(b) Sprinkler Head Flushing - Flush all sprinkler heads as recommended by the manufacturer.

(c) Sprinkler Head Testing - Test for leaks in heads and connections and correct as required.

(d) Main Line Flushing - To remove debris that may have entered the line during construction, flush main supply lines twice with the supply valve fully open. Flush first before placing valves and again after placing valves and before pressure testing.

(e) Main Line Testing - Purge all main supply lines of air and test with static water pressure of at least 150 psi for 60 minutes without introduction of additional service or pumping pressure. Test with one pressure gauge installed on the line where directed. Install an additional pressure gauge at the pump when directed. Lines showing loss of pressure exceeding 5 psi at the end of the specified test period will be rejected. Correct rejected installations and retest for leaks.

(f) Lateral Line Flushing - Flush all lateral lines once with the supply valve fully open prior to placement of sprinkler heads, emitters and drain valves. Flush long enough to remove any debris that enters the lateral lines during construction.

(g) Lateral Line Testing - Purge all lateral lines of air and test under operating line pressures with risers capped and drain valves closed. Maintain operating line pressures for 30 minutes through open valves and pressure regulating devices. Lines showing leaks when visually inspected at the end of the specified test periods will be rejected. Correct and retest lateral line installations that have been rejected.

(h) Lateral Line Alternate Test Method - When conditions prevent effective visual inspection of lateral lines, the Engineer may require that the lines be tested by use of pressure gauges. In that event, maintain the static water pressure equal to the operating line pressure in the lines for 30 minutes, with valves closed and without introduction of additional service pressure. Lateral lines showing loss of pressure exceeding 5 psi at the end of the specified test period will be rejected. Correct and retest lateral line installations that have been rejected.

(i) Testing of Micro Tubing - Micro tubing will be tested by visual inspection while operating and before burial. Tubing that has obvious leaks or that doesn't operate as designed will be rejected. To fully test micro tubing, a water collection procedure recommended by the manufacturer may be required. Correct all faults before retesting.

01120.48 Adjusting System - Before final inspection, adjust and balance all sprinklers to provide adequate and uniform coverage. Balance spray patterns by adjusting individual sprinkler heads with the adjustment screws or by replacing nozzles to produce a uniform pattern. Unless otherwise specified, water spray will not be allowed on pavement, walks or structures.

01120.49 Backfill - Do not start backfill until all piping has been inspected, tested and approved. Complete backfilling as soon as possible after approval. Ensure that backfill material placed within 6 inches of the pipe is free of rocks or other unsuitable material that might cut or otherwise damage the pipe. Backfill from the bottom of the trench to approximately 6 inches above the pipe with continuous compaction in a manner that will not damage the pipe or wiring, and proceed evenly on both sides of the pipe. Thoroughly compact the remainder of the backfill without using heavy equipment within 18 inches of any pipe. Ensure that the top 6 inches of the backfill is topsoil material or, if suitable, is the first 6 inches of material removed in the excavation.

Pipe bedding material conforming to 00405.12 may be authorized in quantities determined by the Engineer. When authorized to proceed, fill the bottom 2 inches of the trench with approved bedding before laying pipe. After the pipe is in position, add enough bedding material to bring the backfill height to 2 inches above the pipe. Continue backfilling as usual.

If sufficient suitable backfill material is not available from trench excavation or other sources on the Project, notify the Engineer. Provide an estimate of imported backfill required, if possible. Unless otherwise shown or specified, imported pipe bedding material will be authorized according to 00140.60.

Maintenance

01120.60 System Operation - Repair, flush and test all main and lateral lines that sustain a break or disruption of service. Upon restoration of the water service, bring the affected lines up to operating pressure. After pressurizing, conduct a thorough inspection of all sprinkler heads, emitters, and other fittings, located downstream of the break or disruption of service, and repair. This inspection is required to ensure that the entire irrigation system is operating properly.

Completely install and test the irrigation system, and make it automatically operable before planting in a unit area except where otherwise shown, specified, or approved. Be fully responsible for all maintenance, repair, testing, inspection and automatic operation of the entire system until Final Acceptance. (see 00150.95)

This responsibility includes, but is not limited to, draining the system before winter and reactivating the system in the spring and at other times as directed.

Be responsible for having annual inspections and tests performed on all cross connection control devices as required by the State Health Division until Final Acceptance. (see 00150.95)

In the spring, when the drip irrigation system is in full operation, make a full inspection of all emitters. This involves visual inspection of each emitter under operating conditions. Make all adjustments, flushing or replacements to the system at this time to ensure the proper operation of all emitters.

01120.61 Drip Line Warranty - Furnish a 5 year manufacturer warranty for the drip tubing according to 00170.85(c-1) against defects in manufacturing, rot, electrolytic corrosion, and stress cracking.

Finishing and Cleaning Up

01120.70 As-Built Plans and System Orientation - Upon completion of the work, submit corrected working drawings, schematic circuit diagrams, or other drawings necessary for the Engineer to prepare corrected plans showing the work as constructed. Provide drawings on 8 1/2 inches by 11 inches, 11 inches by 17 inches, or 22 inches by 36 inches sizes. Prepare and present a training and orientation session covering the operation, adjustment and maintenance of the irrigation system. Review corrected drawings and explain all features. Show locations of drain valves, if any, on the drawings. At this session, provide the Engineer with parts lists and service

manuals for all equipment. Notify the Engineer in writing 2 weeks before the proposed date of the training and orientation session. The date and time of the session will be mutually agreed to.

Measurement

01120.80 Measurement - No measurement of quantities will be made for work performed done under this Section.

Payment

01120.90 Payment - The accepted quantities of work performed under this Section will be paid for at the Contract lump sum amount for the item "Irrigation System".

Payment will be payment in full for furnishing and placing all materials, and for furnishing all equipment, labor, and incidentals necessary to complete the work as specified.

No separate or additional payment will be made for excavation, backfill, electrical service, and system orientation.

Section 01140 - Potable Water Pipe and Fittings

Description

01140.00 Scope - This work consists of constructing potable water pipe and fittings 16 inches and smaller in diameter within a public Right-of-Way or easement.

Materials

01140.10 Materials - Furnish materials meeting the following requirements:

Bolted, Sleeve-Type Couplings for Plain End Pipe.....	02475.60
Commercial Grade Concrete in Thrust Blocks.....	00440
Detectable Marking Tape and Wire	02470.60
Ductile Iron Pipe Fittings.....	02475.20
Ductile Iron Pipe	02470.20
Polyethylene Encasement	02470.50
Polyvinyl Chloride (PVC) Pipe fittings - 4" and larger	02475.40
Polyvinyl Chloride (PVC) Pipe fittings - under 4"	02475.45
Polyvinyl Chloride (PVC) Pipe - 4" and larger.....	02470.40
Polyvinyl Chloride (PVC) Pipe - under 4".....	02470.45
Reinforcement	00530
Restrained Joints.....	02475.50
Steel Pipe Fittings - 6" and larger	02475.30
Steel Pipe Fittings - under 6"	02475.35
Steel Pipe - 6" and larger.....	02470.30
Steel Pipe - under 6".....	02470.35
Tie Rods.....	02485.60

01140.11 Handling Pipe and Fittings - Handle pipe and fittings to prevent damage or contamination to the pipe, fitting, lining, or coating. Load and unload pipe and fittings using hoists and slings so as to avoid shock or damage, and under no circumstances allow them to be dropped, skidded, or rolled against other pipe or fittings. If any part of the coating or lining is damaged, repair in a manner satisfactory to the Engineer. Damaged or contaminated pipe and fittings will be rejected. Immediately separate all damaged or contaminated pipe and fittings and remove from the job site.

(a) Thread Protection - Protect threaded pipe ends with couplings or other means until laid. Inspect the pipe and fittings for defects.

(b) Temporary Storage - Store pipe on cradles to prevent entry of dirt, other foreign material, or contamination. Keep the pipe or pipe joint free of dirt, other foreign material, or contamination during handling or laying operations. Remove, clean, and relay any pipe or fitting that has been installed with dirt, foreign material, or contamination in it. At times when pipe laying is not in progress, close the open ends of pipe with watertight plugs or by other approved means to ensure cleanliness.

01140.12 Cutting Pipe:

(a) General - Use short lengths of pipe supplied by the manufacturer whenever possible to provide the proper spacing of valves, tees or special fittings.

(b) Cutting Operation - Cut pipe with abrasive saws or by special pipe cutters. Square all pipe ends with the longitudinal axis of the pipe. Ream and otherwise smooth the cut ends so that

good connections can be made. Cut threads cleanly. Flame cutting of ductile iron pipe will not be allowed.

Construction

01140.40 Trench Work - Excavate trench, prepare bedding, install pipe zone material, backfill, and dispose of excavated material according to Section 00405 and the following:

(a) Dewatering Trenches - Remove water encountered in the trench during pipe laying operations and maintain the trench until the ends of the pipe are sealed and provision is made to prevent floating of the pipe. Do not allow trench water or other deleterious materials to enter the pipe at any time.

(b) Bedding and Pipe Zone - For the purpose of these Specifications, all potable water pipes are considered flexible pipes. Use bedding and pipe zone material for flexible pipes as described in 00405.12 and 00405.13.

(c) Extra Trench Excavation - Changes in the alignments or grades of the potable water pipes from those shown or specified may be necessary because of unplotted utilities, or for other reasons. If directed to adjust, correct, relocate, or in any way change the line and grade, make such changes according to these Specifications.

(d) Grade and Alignment Changes - When pipeline grade is lowered in excess of 12 inches below the grade shown, or when pipeline horizontal alignment is changed by more than 12 inches after the original trench has been excavated, the additional excavation and backfill so required will be classified as extra trench excavation. The additional backfill material shall match the class used in the original trench.

(e) Installation in Paved Areas - If pipe is installed within paved areas to be preserved, perform the installation according to Sections 00405 and 00495.

01140.41 Laying Pipe:

(a) General - Lay pipe to the lines and grades shown and established.

(b) Ductile Iron Pipe - Install ductile iron pipe according to AWWA C600 and the manufacturer's recommendations.

(1) Curves - Lay long radius curves, either horizontal or vertical, with standard pipe by deflecting the joints. If the pipe is shown curved in the plans and no special fittings are shown, assume that the curves can be made by deflecting the joints with standard lengths of pipe. If shorter lengths are required, the plans will indicate maximum lengths that can be used. Do not exceed 80 percent of the manufacturer's printed recommendations for the amount of deflection at each pipe joint when pipe is laid on a horizontal or vertical curve. Where field conditions require deflection or curves not anticipated by the plans, the Engineer will determine the methods to be used.

(2) Pipe Laying Procedure - When ductile iron pipe is laid on a curve, join the pipe in a straight alignment and then deflect it to the curved alignment. On approval, make trenches wider on curves for this purpose.

(c) Polyethylene Encasement - Where shown, lay ductile iron pipe with a polyethylene encasement. Install polyethylene encasement according to AWWA C105 and the manufacturer's recommendations.

(d) Steel Pipe - Install steel pipe according to the manufacturer's recommendations. Lay steel pipe on curves in the same manner described above for ductile iron pipe.

(e) Polyvinyl Chloride Pipe - Install polyvinyl chloride (PVC) pipe according to AWWA C605 and the manufacturer's recommendations.

(1) Bends - Bend PVC pipe 12 inches and smaller to allow for slight changes in direction. The minimum bending radius shall be according to AWWA C605. Axial deflection at the pipe joints will not be allowed.

(2) Large Diameter Pipe - For 14 inch and 16 inch diameter pipe, accomplish slight changes in direction by axial deflection of the pipe joint not to exceed 80 percent of the manufacturer's recommendation. Use fittings for joint deflections greater than 80 percent of the manufacturer's recommendation.

(f) Water and Sanitary Sewer Separation - Comply with OAR 333 regulations governing horizontal and vertical separation between water and sanitary sewer facilities for installation of new water lines and appurtenances. Submit any proposal for variance in writing. Include in the proposal the reason for the variance, type of material and condition of the sewer line, location of the water and sewer facilities, horizontal and vertical skin-to-skin clearances and the corrective measures proposed. The proposal will be reviewed and approved by the Engineer. Each variance will be addressed in a case-by-case basis.

01140.42 Jointing Pipe:

(a) General - Clean all parts of the pipe ends, couplings, fittings, and appurtenances to remove oil, grit, or other foreign matter from the joint. Keep the joint from contacting the ground. When assembling gasketed joints, apply an approved lubricant as specified by the pipe manufacturer.

Mark pipe not furnished with a depth mark before joint assembly.

(b) Steel Pipe Under 6 Inches - Brush-coat exposed threads after jointing with an approved asphalt coating.

01140.43 Polyethylene Encasement:

(a) Installation - Install polyethylene encasement according to AWWA C105 except as modified by these Specifications. Wrap polyethylene encasement loosely around the pipe, fittings, and couplings, and secure with 2 inch wide polyethylene adhesive tape. Cover joints or seams in the polyethylene encasement using 2 inch wide polyethylene adhesive tape. The polyethylene encasement need not be watertight, but do not expose any part of the pipe or coupling to the backfill. Exercise care during backfilling to prevent puncturing or otherwise damaging the polyethylene encasement.

(b) Connections - When connecting to existing polyethylene-encased pipe, cut the existing encasement within 1 foot of the connection couplings or fittings. After the connections are made, overlap the exiting polyethylene encasement a minimum of 3 feet and seal the overlaps with 2 inch wide polyethylene adhesive tape.

01140.44 Thrust Restraint:

(a) Concrete Thrust Blocks - Place concrete thrust blocks as shown, at bends, tees, dead ends, and crosses. Pour concrete thrust blocks in place against solid, undisturbed earth at the sides and bottom of the trench excavation. Shape the blocks so as not to obstruct access to the joints of the pipe or fittings.

(b) Restrained Joints - Where indicated or approved by the Engineer, restrain joints at bends, tees dead ends, crosses, and all pipe joints within the indicated or specified distance on each side of the bends, tees, dead ends, and crosses. Install joint restraint systems according to the manufacturer's recommendations.

01140.45 Marking Tape and Wire:

(a) Installation - Install marking tape and wire over all nonmetallic water lines, including service connections. Place a continuous solid copper wire along the top of all water pipe, including service lines. Secure to the top of the pipe at maximum 10 foot intervals using 6 inch strips of 2 inch wide duct tape. Tie all splices and make them electrically continuous and waterproof. Provide access to terminal ends of the wire at all valve boxes, meter boxes, fire hydrants, and vaults. The result of this installation shall be a continuous wire circuit electrically isolated from ground. Place the marking tape approximately 1 foot above the top of the pipe for its full length.

(b) Accessibility - Make ends of wire accessible in water meter boxes, valve boxes or casings, or outside the foundation of buildings where the pipe enters the building. Provide wire access at locations no more than 1,000 feet apart.

(c) Testing - Test for continuity and isolation from ground in the wire after all work has been completed on the test section. Perform intermediate testing after backfilling operations and prior to surface restoration work. Test continuity between access locations by use of a temporary wire connecting test points in-line with an ohmmeter. Measure resistance with an approved ohmmeter that has been properly calibrated. The continuity of a test section will be accepted if the resistance of the test section does not exceed 5 ohms for each 500 feet of location wire being tested. Measure isolation from ground with an approved 1000 volt Megger, applied for 1 minute. The isolation of a test section will be accepted if the isolation resistance of the test section is at least 10 megohms. Locate and repair all breaks or defects in the wire and re-test until specified results are obtained.

01140.46 Blowoff Assemblies - Construct blowoff assemblies as shown and at the locations shown.

01140.47 Connections to Existing Mains - Make necessary arrangements with the Engineer in advance of connections to existing water mains. Assemble all materials, equipment and labor necessary to properly complete the work before starting.

(a) Notification - If the connection to the existing system involves turning off the water, notify the residents affected by the shutoff. The Engineer will advise which property owners are to be notified.

(b) Permission - The work to perform the connection may need to be carried out during times other than normal working hours. Do not operate any valves on the existing system without specific permission of the Engineer.

(c) Connection Arrangements - Piping arrangements shown are suggestions. For connection by any other arrangement, furnish a detailed sketch for approval not less than 2 weeks prior to the expected construction.

(d) Uninterrupted Service - Once work is started on a connection, proceed continuously without interruption, and as rapidly as possible, until completed. Shutoff of mains will not be allowed overnight, over weekends, or on holidays.

(e) Cutting Main Lines - Cut existing water mains according to 01140.12. Remove the portions of pipe to provide for the installation of the required fittings at the points of connection. Repair all damage to existing joints in piping to remain in-service. Determine the exact length of the existing water main that is to be removed. Bevel pipe ends to prevent damage to the transition coupling gasket during installation of the coupling. Clean the exterior of the existing pipe end to a sound, smooth finish before installation of the coupling.

01140.48 Maintaining Service:

(a) Service Transfer - Where existing services are to be transferred from old to new mains, plan and coordinate the work with that of the Utility so that service will be resumed with the least possible inconvenience to the public.

(b) Connections by Utility - Allow the Utility to make connections into the new pipe at such locations as the Utility may elect to supply customers with water, after the affected section of pipe has passed hydrostatic and bacteriological tests. The installation of any such connections by the Utility shall not be construed as an acceptance by the Agency of any part of the work required under the Contract.

01140.49 Backfilling - After the pipe is installed and inspected, backfill the trench according to Section 00405.

Field Testing

01140.50 Filling and Flushing - Fill pipes slowly with potable water at a maximum velocity of 1 foot per second while venting all air. Take all required precautions to prevent entrapping air in the pipes.

(a) Flush and Disinfect - Flush sections of pipe to be tested and disinfect to remove any solids or contaminated material that may have become lodged in the pipe. If no hydrant is installed at the end of the main, provide a tap large enough to develop a velocity of at least 2.5 feet per second in the main.

(b) Taps - Provide taps for temporary or permanent release of air, flushing, or chlorination.

(c) Disposal of Treated Water - Dispose of treated water flushed from mains. Neutralize the waste water for protection of aquatic life in the receiving water before disposal into any natural drainage channel. Dispose of disinfecting solution to the satisfaction of the Engineer and local authorities. If approved by the Engineer and the Utility, disposal may be made to any available sanitary sewer provided the rate of disposal will not overload the sewer.

01140.51 Hydrostatic Testing:

(a) General - Test all water mains and appurtenances in sections of convenient length under a hydrostatic pressure equal to one and one-half times the working pressure, but at least 150 psi, measured at the highest point of the test section. Furnish and operate all pumps, gauges, plugs, saddles, corporation stops, miscellaneous hose and piping, and measuring equipment necessary for performing the test. Provide certifications of accuracy for gauges used in the test from an approved laboratory.

(1) Backfill - Backfill the pipeline sufficiently to prevent movement of the pipe under pressure. Place all thrust blocks and allow time for the concrete to cure before testing. Where permanent blocking is not required, furnish and install temporary blocking and remove it after testing.

(2) Filling Pipe - Fill the mains with water and allow to stand under pressure a sufficient length of time to allow the escape of air and to allow the lining of the pipe to absorb water. The Agency will furnish the water necessary to fill the pipelines for testing, at a time of day when sufficient quantities of water are available for normal system operation.

(3) Time Test - Test by pumping the main up to the required pressure for at least 2 hours. Provide additional pumping during the test period to continuously maintain pressure within 5 psi of that required. During the test, observe the section being tested to detect any visible leakage. Use a clean container to hold water for pumping up pressure on the main being tested. Sterilize this makeup water by adding chlorine to a concentration of 25 ppm.

(4) Measure Quantity - Accurately determine the quantity of water required to maintain and restore the required pressure at the end of the test period by pumping through an approved positive displacement water meter.

(5) Loss Formula - The quantity of water lost from the main shall not exceed the number of gallons per hour determined by the formula:

$$L = \frac{SD(P)^{1/2}}{148,000}$$

Where:

- L = allowable leakage in gallons per hour
- S = length of pipeline tested in feet
- D = nominal diameter of the pipe in inches
- P = average test pressure during the leakage test in psi

(6) Pressure Loss - There shall be no appreciable or abrupt loss in pressure during the test period.

(7) Leakage - Correct all visible leakage regardless of the allowable leakage specified above. If the actual leakage exceeds the allowable amount, locate and repair the leaks and retest the pipeline.

(8) Use of Hydrant Valves - Make all tests with the hydrant auxiliary gate valves open and pressure against the hydrant valve. After the pipe test has been completed, test each gate valve in turn by closing it and relieving the pressure beyond. This test of the gate valve will be acceptable if there is no immediate loss of pressure on the gauge when the pressure beyond the valve is relieved. Verify that the pressure differential across the valve does not exceed the rated working pressure of the valve.

(9) Test Section Length - Limit sections to be tested to 1,500 feet, unless longer test sections are approved. The Engineer may require that the first installed section of pipe installed by each crew, not less than 1,000 feet in length, be tested. Do not continue pipe laying more than an additional 1,000 feet until the first section has been tested successfully.

(10) Test Equipment Readiness - Prior to calling out the Engineer to witness the pressure test, set up all equipment completely ready for operation and successfully perform the test to ensure that the pipe is in a satisfactory condition.

(11) Defective Materials or Workmanship - Replace defective materials or workmanship discovered during hydrostatic field testing. Whenever it is necessary to replace defective material or correct the workmanship, repeat the hydrostatic test until a satisfactory test is obtained.

(b) Testing Extensions from Existing Mains:

(1) Exceptions - When an existing water main is extended with new pipe to a new valve, and the distance from the existing pipe to the new valve is 18 feet or less, no hydrostatic test will be required if the section of new pipe between the new valve and the end of the existing main is installed with pretested, prechlorinated pipe. When the required hydrostatic tests are conducted in the new main section beyond the installed new valve in the closed position, the normal pressure of the existing main may be present against the other side of the new valve.

(2) Required Testing - Where the distance between the end of an existing water main pipe extension and the new valve is more than 18 feet, do not connect the new pipe to the existing pipe until after hydrostatic tests have been made to the required pressure in both directions against the new valve. Test after installing a temporary cap or plug on the end of the new pipe, beyond the new valve, as close as possible to the existing pipe. Make the final connection to the existing main with pretested, prechlorinated pipe.

(c) Testing Sections with Hydrants Installed - When hydrants are included with the section of main pipe to be tested, conduct three separate tests as shown in the following table:

	Water Main Gate Valves	Hydrant Auxiliary Gate Valves	Hydrant Operating Stem Valves	Hose Ports
Test No. 1	Closed	Closed	Wide Open	Wide Open
Test No. 2	Closed	Wide Open	Closed	Wide Open
Test No. 3¹	–	Closed	Wide Open	Closed

¹ Test each hydrant to the required test pressure. When testing a hydrant singly, pressure in the supply main beyond the hydrant auxiliary gate valve shall be 25 psi.

(d) Testing Hydrants Installed on Existing Mains - For hydrants installed and connected to existing mains, install the hydrant connection, including hydrant tee, connection pipe and auxiliary gate valves, with pretested materials.

Before the hydrant connection is made to the existing main, subject the hydrant installation to hydrostatic Test No. 3 in 01140.51(c).

01140.52 Disinfecting:

(a) General - Before placing new water mains in service, chlorinate new mains and repaired portions of, or extensions to, existing mains and obtain a satisfactory bacteriological report.

The initial chlorine content of the water shall be not less than 25 ppm. A chlorine residual of not less than 10 ppm shall remain in the water after standing 24 hours in the pipe.

(b) Chlorine Application - Apply chlorine by one of the following methods:

(1) Gaseous Chlorine - Apply a chlorine gas-water mixture by means of a solution-feed chlorinating device, or feed the dry gas directly through proper devices for regulating the rate of flow and providing effective diffusion of the gas into the water within the pipe being treated. Chlorinating devices for feeding solutions of the chlorine gas, or the gas itself, shall provide means for preventing the backflow of water into the chlorine.

(2) Calcium Hypochlorite - Apply a mixture of water and high-test calcium hypochlorite (65 - 70 percent Cl). First mix the dry powder as a paste and then thin to a 1 percent chlorine solution by adding water to give a total quantity of 7.5 gallons per pound (water to dry powder).

- (3) Sodium Hypochlorite** - Apply sodium hypochlorite, commercial grade (12.5 percent Cl) or in the form of liquid household bleach (5 - 6 percent Cl). This liquid chlorine compound may be used full strength or diluted with water.
- (c) Point of Application** - Apply the chlorinating agent at the beginning of the pipeline extension or any valved section of it, through a corporation stop inserted in the horizontal axis of the pipe. Supply the water injector for delivering the chlorine-bearing water into the pipe from a tap on the pressure side of the gate valve controlling the flow into the pipeline extension. Alternate points of applications may be used when approved.
- (d) Rate of Application** - Control water from the existing distribution system, or other source of supply, to flow very slowly into the newly laid pipeline during application of the chlorine. The rate of chlorine application shall be in such proportion to the rate of water entering the newly laid pipe that the initial chlorine content of the water will be at least 25 ppm.
- (e) Cross Connection Control** - Make no connections between the existing distribution system and non-disinfected pipelines constructed under this Contract, unless a State Health Division approved backflow preventer is installed in the connecting line.
- (f) Retention Period** - Retain chlorinated water in the pipe at least 24 hours. After this period, the residual chlorine at pipe extremities and at other representative points shall be at least 10 ppm.
- (g) Chlorinating Connections to Existing Water Mains** - Follow the chlorinating procedure specified in AWWA Standard C651. Liberally treat the trench and exterior of existing main with hypochlorites. Swab or spray the interior of all closure fittings with a 1 percent hypochlorite solution. Disinfect the existing main with a 100 ppm chlorine solution for 3 hours or a 300 ppm chlorine solution for 15 minutes and then thoroughly flush the line.
- (h) Flushing and Testing** - Following the retention period, flush all chlorinated water from the newly laid pipe until the replacement water throughout its length shows, upon test, an absence of chlorine or a residual no greater than that normally found in the source of supply.
- (1) Sampling Tap** - Install a sampling tap ahead of the flushing hose for convenient sanitary sampling.
- (2) Service Resumption** - Do not place the lines into service before a satisfactory report is received from the local or State health department on samples collected from representative points in the new system. Samples will be collected and bacteriological tests obtained by the Engineer.
- (i) Repetition of Chlorinating and Testing** - If the initial treatment results in a chlorine residual of less than 10 ppm at the end of the retention period or an unsatisfactory bacteriological test, repeat the original chlorination procedure until satisfactory results are obtained.

Measurement

01140.80 Measurement - The quantities of potable water pipe and fittings will be determined as follows:

- (a) Pipe, Fittings and Couplings** - The quantities of pipe of the various kinds, types, sizes and backfill classes will be measured on the length basis and will be horizontal measurement along the top of the finished trench, with no deduction for fittings, valves, and couplings.

In addition to measurement of the pipe, an allowance of 12 pipe diameters will be made for each factory-fabricated bend, sleeve, reducer or coupling, and an allowance of 18 pipe diameters of the larger diameter pipe will be made for each factory-fabricated tee or cross. The allowance will be added to the quantity for pipe of the same diameter.

(b) Extra Trench Excavation - The quantities of removal and backfill of extra trench excavation will be measured on the volume basis for each backfill class. The backfill classes are defined in Section 00405. The depth will be the actual depth removed for the changed line or grade as directed. The width will be the actual width removed for the changed line or grade, but in no case will the measured width exceed the allowable widths specified in 00405.41(c).

(c) Blowoff Assemblies - The quantities of blowoff assemblies will be measured on the unit basis.

(d) Connections to Existing Mains - The quantities of connections to existing mains will be measured on the unit basis.

Trench resurfacing will be measured according to 00495.80.

Installation under pavement by tunneling, jacking, or boring methods will be measured according to 00406.80.

Valves will be measured according to 01150.80.

Payment

01140.90 Payment - The accepted quantities of work performed under this Section will be paid for at the Contract unit price, per unit of measurement, for the following items:

Pay Item	Unit of Measurement
(a) ___ Inch Potable Water Pipe, Fittings and Couplings with Class ___ Backfill	Foot
(b) ___ Inch Potable Water Pipe, Fittings and Couplings with Restrained Joints and Class ___ Backfill	Foot
(c) Extra Trench Excavation with Class ___ Backfill	Cubic Yard
(d) Blowoff Assembly, ___ Inch	Each
(e) ___ Inch Connection to ___ Inch Existing Main	Each

The Contract unit price for the appropriate pay items reflects plan requirements or the Contractor's choice from the applicable options listed on the Pipe Data Sheets if shown.

In items (a) and (b), the nominal diameter of pipe, fittings and couplings will be inserted in the first blank. The class of backfill will be inserted in the second blank. The quantities include the pipe plus the allowance for the fittings and couplings.

In item (c), the class of backfill will be inserted in the blank.

In item (d), the nominal diameter of assembly will be inserted in the blank.

In item (e) the nominal diameter of pipe will be inserted in the first blank and the nominal diameter of the main line will be inserted in the second blank.

Payment will be payment in full for furnishing and placing all materials, and for furnishing all equipment, labor, and incidentals necessary to complete the work as specified.

Trench resurfacing will be paid for according to 00495.90.

Installation under pavement by tunneling, jacking or boring methods will be paid for according to 00406.90.

Valves will be paid for according to 01150.90.

No separate or additional payment will be made for:

- trench excavation
- bedding
- pipe zone material
- backfill work
- polyethylene encasement
- concrete thrust blocks
- detectable marking tape and wire
- flushing, hydrostatic testing and disinfection, and water for testing
- exposing and cleaning existing mains, cutting and removing existing pipe, draining existing mains, disinfecting existing mains, and refilling existing mains

Section 01150 - Potable Water Valves

Description

01150.00 Scope - This work consists of furnishing and installing valves in potable water systems at the locations shown or at other locations as directed.

Materials

01150.10 Materials - Furnish materials meeting the following requirements:

Backflow Prevention Devices	02480.70
Ball Valves	02480.23
Butterfly Valves	02480.22
Combination Air Release/Air Vacuum Valves	02480.60
Commercial Grade Concrete in Precast Concrete Blocks.....	00440
Commercial Grade concrete in Thrust Blocking	00440
Gate Valves.....	02480.20
Hydraulic Cushion Check Valves	02480.40(c)
Hydraulically Operated Valves	02480.50
Power-Actuating Devices	02480.24
Spring-Loaded Plug or Disc Check Valves.....	02480.40(b)
Swing Check Valves.....	02480.40(a)
Tapping Sleeve and Valve Assemblies	02480.30
Valve Boxes	02480.25
Valve Stem Extensions	02480.26

01150.11 Handling - Handle valves so as to prevent damage to the valve, lining or coating. Load and unload valves using hoists and slings so as to avoid shock or damage, and under no circumstances allow them to be dropped or skidded. Damaged valves will be rejected. If damage is confined to the coating or lining, it may be repaired in a manner satisfactory to the Engineer. Immediately place all damaged valves apart from the undamaged and remove the damaged valves from the site as soon as possible.

01150.12 Connecting Ends - Furnish valves with connecting ends as shown and as required for connection to pipe and fittings furnished.

Construction

01150.40 General - Install valves according to the plans and the manufacturer's recommendations. Join to the pipe according to Section 01140 and AWWA Standards for the type of connecting ends furnished. Thoroughly clean and repair joints prior to installation.

(a) Valve and Valve Box Installation - Set valves and valve boxes plumb. Install valve stem extensions when required. Center the valve box over the operating nut of the valve. Place valve boxes over the valve or valve operator so that the valve box does not transmit shock or stress to the valve. Install the lower casting of the unit first, supported by backfill or by a closed-cell foam collar not less than 2 inches in thickness. Do not allow the casting to rest directly on the body of the valve or on the water main.

(b) Valve Operator Extensions - Install a valve operator extension with rock guard on any valve that has the valve nut operator installed 4 feet or more below finish grade. Hot-dip galvanize extensions after fabrication.

(c) Backfilling - Backfill around valves according to Section 00405. Carefully tamp backfill around the valve box to a distance of 3 feet on all sides or to the undisturbed face of the trench, whichever is closer. Set the cast iron valve box cover flush with the roadbed or finished paved surface.

01150.41 Combination Air Release/Air Vacuum Valves - Install combination air release/air vacuum valves as shown. Slope all piping to permit escape of any entrapped air. Perform trenching and backfilling according to 01170.40 and Section 00405.

01150.50 Field Testing - After installation, operate valves from full open to full closed to make sure valves do not bind during operation. Correct all malfunctions in the operation of the valves. Verify the number of turns from full open to full closed and provide to the Engineer for the Agency's records.

01150.51 Hydrostatic Testing - Subject valves to hydrostatic testing according to 01140.51. Correct all defects in design, materials or workmanship to the satisfaction of the Engineer.

01150.52 Disinfecting - Disinfect valves according to 01140.52.

Measurement

01150.80 Measurement - The quantities of valves will be measured on the unit basis.

Payment

01150.90 Payment - The accepted quantities of work performed under this Section will be paid for at the Contract unit price, per unit of measurement, for the following items:

Pay Item	Unit of Measurement
(a) ___ Inch ___ Valve	Each
(b) ___ Inch ___ Valve With ___ Actuator	Each
(c) ___ Inch ___ Check Valve	Each
(d) ___ Inch ___ Backflow Prevention Assembly	Each
(e) ___ Inch Hydraulically Operated Valve	Each
(f) ___ Inch Combination Air Release/Air Vacuum Valve Assembly	Each
(g) ___ Inch Tapping Sleeve and ___ Inch Valve Assembly	Each

In items (a) through (f), the size of the valve or assembly will be inserted in the first blank.

In items (a) through (d), the type of valve, check valve, or assembly will be inserted in the second blank.

In item (b), the type of actuator will be inserted in the third blank.

In item (g), the size of tapping sleeve will be inserted in the first blank. The size of valve assembly will be inserted in the second blank.

Payment will be payment in full for furnishing and placing all materials, and for furnishing all equipment, labor, and incidentals necessary to complete the work as specified.

No separate or additional payment will be made for earthwork not covered under other pay items, jointing, blocking of valves, protective coatings, valve boxes, valve stem extensions, and hydrostatic testing.

Section 01160 - Hydrants and Appurtenances

Description

01160.00 Scope - This work consists of furnishing and installing dry-barrel fire hydrants and appurtenances in potable water systems at the locations shown or at other locations as directed.

Materials

01160.10 Materials - Furnish materials meeting the following requirements:

Auxiliary Gate Valves	02480.20
Commercial Grade Concrete in Thrust Blocking	00440
End Connections	02485.20
Fire Hydrants.....	02485.10
Guard Posts	02485.70
Hydrant Dimensions	02485.30
Hydrant Extensions	02485.40
Tie Rods.....	02485.60
Traffic Flange	02485.50
Valve Boxes	02480.25
Valve Stem Extensions	02480.26

01160.11 Handling of Hydrants:

(a) Loading and Unloading - Handle hydrants to prevent damage to the hydrant, lining or coating. Load and unload hydrants using hoists and slings so as to avoid shock or damage, and under no circumstances allow them to be dropped, skidded or rolled against other hydrants. Damaged hydrants will be rejected. If damage is confined to the coating or lining, it may be repaired in a manner satisfactory to the Engineer. Immediately place all damaged hydrants apart from the undamaged and remove the damaged hydrants from the site as soon as possible.

(b) End Caps - Provide factory applied end cap on pipe connection end. Maintain end cap through shipping, storage, and handling to prevent damage and prevent dirt and moisture from entering the hydrant.

Construction

01160.40 Setting Hydrants - Inspect all hydrants upon delivery in the field to ensure proper working order. Provide a minimum 5 foot radius unobstructed working area around all hydrants. Set the traffic flange 2 inches above finish grade. Allow the hydrant barrel drain to waste into a pit of porous gravel material situated at the base of the hydrant.

(a) Touchup Painting - After all installation and testing is complete, paint the exposed portion of the hydrant with one coat of the type and color coating designated by the Engineer.

(b) Out-of-Service Hydrants - Identify all hydrants not in service by covering with a burlap or plastic bag properly secured.

01160.41 Hydrant Laterals - Install hydrant laterals, consisting of 6 inch ductile iron pipe, from the auxiliary gate valve at the main to the hydrant, according to Section 01140 and as shown.

01160.42 Hydrant Restraints - Restrain the thrust created in the hydrant lateral as shown. If applicable, clean tie rods after installation and paint with two coats of coal tar epoxy or other approved bituminous coating.

01160.43 Auxiliary Gate Valves and Valve Boxes - Install auxiliary gate valves and valve boxes according to Section 01150, except that the end connections shall be provided with lugs for tie rods, or the bells shall provide sufficient clearance between the body of the valve and the hub to permit the installation of tie rods.

01160.44 Hydrant Guard Posts - Construct hydrant guard posts at the locations shown. Excavate holes 6 inches in diameter for hydrant guard posts to a depth of 36 inches. Install hydrant guard posts plumb, and center in the holes. Backfill the holes and fill the hydrant guard posts with commercial grade concrete. Paint the exposed portion of each guard post with one coat of the type and color coating designated by the Engineer.

01160.45 Resetting Existing Hydrants:

(a) Relocation - Where existing hydrants are shown for adjustments to conform to a new street alignment or grade, or both, relocate the hydrant without disturbing the location of the hydrant lateral tee at the main.

(b) Thrust Restraint - Determine the method for thrust restraint for the hydrant lateral according to the conditions found in the field, and construct as directed.

01160.46 Moving Existing Hydrants - Move existing hydrants where shown. When the existing hydrant lateral tee does not accommodate a new hydrant location, install a new hydrant lateral tee in the main. Remove the existing hydrant lateral tee from the main if the main is to remain active, and insert a new section of pipe into the water main in place of the existing hydrant lateral tee. Where the existing main to which the existing hydrant lateral tee is connected is to be abandoned or temporarily activated after the existing hydrant is moved, plug the open end of the hydrant lateral pipeline. Provide temporary thrust restraint if temporarily reactivated.

01160.47 Reconnecting Existing Hydrants - Reconnect existing hydrants where shown. Leave the location and elevation of the existing hydrant unchanged, but change the existing hydrant lateral to connect with a new auxiliary gate valve and hydrant tee provided in a new main. Install new hydrant lateral according to Section 01140 where the lateral extends to connect to the new main. Where existing hydrants were not restrained with tie rods to the old main, restrain the new connections with tie rods as shown, or by other joint restraint method as directed.

01160.48 Hydrant Extensions - Install hydrant extensions where required. Set the traffic flanges a minimum of 2 inches and a maximum of 6 inches above finish grade.

Field Testing Installations

01160.50 General - After installation, operate hydrants from full open to full closed to make sure they do not bind during operation. Correct all malfunctions in the operation of the hydrants.

01160.51 Hydrostatic Testing - Subject hydrants to hydrostatic testing according to 01140.51. Correct all defects in design, materials or workmanship to the satisfaction of the Engineer.

01160.52 Disinfecting - Disinfect hydrants according to 01140.52.

Measurement

01160.80 Measurement - The quantities of work performed under this Section will be measured on the unit basis.

New pipe for hydrant connections to existing mains and lateral tees will be measured according to 01140.80.

Payment

01160.90 Payment - The accepted quantities of work performed under this Section will be paid for at the Contract unit price, per unit of measurement, for the following items:

Pay Item	Unit of Measurement
(a) Hydrant Assemblies	Each
(b) Resetting Existing Hydrants	Each
(c) Moving Existing Hydrants.....	Each
(d) Reconnecting Existing Hydrants	Each
(e) Hydrant Guard Posts	Each
(f) Hydrant Extensions.....	Each

Item (a) includes auxiliary gate valves, tie rods, concrete blocks, gravel, and painting.

Item (b) includes tie rods, painting, and reconnecting to the main.

Item (c) includes new hydrant lateral tee, tie rods, painting, reconnecting to the main, and plugging abandoned laterals if needed.

Item (e) includes excavation, backfill, and painting.

Payment will be payment in full for furnishing and placing all materials, and for furnishing all equipment, labor, and incidentals necessary to complete the work as specified.

New pipe for hydrant connections to existing mains and lateral tees will be paid for according to 01140.90.

Section 01170 - Potable Water Service Connections, 2 Inch and Smaller

Description

01170.00 Scope - This work consists of furnishing and installing service connections, 2 inch in diameter and smaller, from the main to the water meter, and furnishing and installing sampling stations. The water meter will be furnished and installed by others unless specified otherwise in the Special Provisions or on the plans.

Materials

01170.10 Materials - Furnish materials meeting the following requirements:

Bronze Nipples and Fittings	02490.60
Copper Tubing Service Pipe	02490.40(a)
Corporation Stops	02490.30
Meter Boxes	02490.70
Meter Setters.....	02490.50
Polyethylene Tubing Service Pipe.....	02490.40(b)
Saddles	02490.20
Sampling Stations	02490.80
Service Fittings.....	02490.40(c)

Construction

01170.40 General - Make all service connections to water mains, except to ductile iron pipe, Thickness Class 52 or thicker, using saddles as specified and of the size and type suitable for use with the water main and the pipe being installed. Direct tap ductile iron pipe, Thickness Class 52 or thicker, for corporation stops according to the recommendations of the Ductile Iron Pipe Research Association (DIPRA), unless direct taps are prohibited by the Special Provisions. Install service pipelines perpendicular to the main, unless shown otherwise.

(a) Trench Depth - Construct the depth of trench for service connection piping to provide a minimum of 30 inches of cover over the top of the pipe. Exercise care to ensure that the main is not damaged by the work undertaken to install the service. Excavate and backfill for service connections according to Section 00405, except install the service pipeline under pavement, curbs and sidewalks by boring methods approved by the agency having jurisdiction over the roadway.

(b) Installation - Make service connections to water mains according to pipe manufacturer's recommendations and appropriate AWWA standard for water main installation. Cut service pipes using tools specifically designed to leave a smooth, even and square end on the pipe. Ream cut ends to the full inside diameter of the pipe. Clean pipe ends to be connected using couplings that seal to the outside surface of the pipe to a sound, smooth finish before the couplings are installed. Adjust the meter box to the finished grade after the surface has been acceptably restored.

01170.41 Reconnecting Existing Services - Where shown, reconnect existing service connections to the new mains. Verify the location of existing service connections in the field. Notify affected customers of the service interruption at least 24 hours prior to service interruption. Use insulating couplings at all connections between existing galvanized steel or iron pipe and new copper pipe. All fittings, appurtenances, and other miscellaneous materials on the sections of existing pipe that have been removed become the property of the Contractor.

01170.42 Sampling Stations - Install sampling stations according to the manufacturer's recommendations and at the locations and depths shown or as directed. Perform trenching and backfilling according to 01170.40.

Field Testing Installations

01170.50 Flushing and Disinfecting - For installation of service connections and sampling stations to existing water mains, liberally treat the trench and exterior of existing main with hypochlorites. Swab or spray all service pipe, appurtenances, and sampling stations with a 1 percent hypochlorite solution. Disinfect service connections and sampling stations with a 100 ppm chlorine solution for 3 hours or a 300 ppm chlorine solution for 15 minutes and then thoroughly flush the service connections and sampling stations. For installation of service connections and sampling stations concurrent with new water mains, flush and disinfect service connections and sampling stations according to Section 01140.

01170.51 Hydrostatic Testing - For installation of service connections and sampling stations to existing water mains, apply system pressure to new installation prior to backfilling and repair any visible leaks. For installation of service connections and sampling stations concurrent with new water mains, perform hydrostatic testing of service connections and sampling stations according to Section 01140. Correct all defects in materials or workmanship and retest until satisfactory results are obtained.

Measurement

01170.80 Measurement - The quantities of service connections, reconnecting existing services, and sampling stations will be measured on the unit basis.

Payment

01170.90 Payment - The accepted quantities of work performed under this Section will be paid for at the Contract unit price, per unit of measurement, for the following items:

Pay Item	Unit of Measurement
(a) ___ Inch Water Service Connections.....	Each
(b) Reconnecting Existing Water Services, ___ Inch.....	Each
(c) Water Sampling Stations	Each

In items (a) and (b), the size will be inserted in the blank.

Item (a) includes excavating, tapping the main, laying and jointing the pipe and fittings and appurtenances, backfilling, testing, flushing and disinfection of the service connection.

Item (b) includes excavation, tapping the main, laying and jointing the pipe and fittings and appurtenances, backfilling, testing, flushing and disinfection of the reconnected service connection.

Item (c) includes excavating, tapping the main, laying and jointing the pipe and fittings and appurtenances, backfilling, concrete pad, testing, flushing and disinfection of the sampling station.

Payment will be payment in full for furnishing and placing all materials, and for furnishing all equipment, labor, and incidentals necessary to complete the work as specified.