

SECTION 02520 - STEEL AND CONCRETE PILES

(Follow all instructions. If there are no instructions above a subsection, paragraph, sentence, or bullet, then include them in the project. The specifications may be modified to include project specific specifications, but all additions, deletions, or modifications must be sent to the ODOT Technical Resource and Senior Specifications Engineer for review and approval.)

Comply with Section 02520 of the Standard Specifications modified as follows:

02520.10(b) Steel Pipe Piles - Replace the sentence that begins "Steel pipe piles shall be..." with the following sentence:

Steel pipe piles shall be either spirally welded or longitudinally welded, constant in section, and conforming to ASTM A 252, Grade 2 or 3, or API 5L X42 or X52.