

**RED Underlined** = Existing Oregon Amendment brought forward from the 2007 OFC  
**BLUE or ~~BLUE Strikethrough~~** = Oregon Deletion or NOT ADOPTED  
**TEAL Underlined** = New Oregon Amendment in the 2010 OFC

## CHAPTER 18

### SEMICONDUCTOR FABRICATION FACILITIES

**1803.7.3 Hazardous production material (HPM) rooms, gas rooms and liquid storage rooms.** Electrical wiring and equipment in HPM rooms, gas rooms and liquid storage rooms shall comply with NFPA 70.

**NOTE: HPM facilities are also regulated by the State of Oregon, Building Codes Division, Administrative Rules Chapter 918, Division 306.**