

Errata for the 2007 Oregon Fire Code

Last update January 7, 2009

~~Strikethrough~~ text represents deleted language.

Underlined text represents added language.

- 1) On page 68, Table 803.3 there should be footnotes k and m at the end of the title. The letter m is missing.
- 2) On page 238, Section 2404.17.2 part of the paragraph was not printed. Please cutout the following paragraph and place it over the existing.

2404.17.2 Flammable and combustible liquid storage.
 Flammable and combustible liquids shall be stored outside in an approved manner not less than 50 feet (15 240 mm) from tents, canopies or membrane structures. Storage shall be in accordance with Chapter 34.

- 3) **1027.1.1 Determining the adequacy of the means of egress.** In determining the adequacy of the means of egress, as required by OAR 837-04100050(2)(d), the fire code official may be guided by the requirement specified in Sections ~~1026.2~~ 1027.2 through ~~1026.21~~ 1027.21.
- 4) **Appendix Table SR109.1**, Page 440. In the Evacuation Capability and Number of Residents column the following <5 need a line under the < symbol. This symbol should read less than or equal to ≤.

R-3	SR-3.3	Personal Care: Private Residential Schools and Other Similar Services, residential Treatment Homes, Adult Residential with Child Care, Residential Transition Programs, 24 Hour residential Services/Duplexes Apartments, 24 Hour Community Residential Services Small Group Homes	Self Preservation ≤ 5
R-3 & Appendix SR SR-3	SR-3.3 & SR-2.3	Personal Care: Private Residential Schools and Other Similar Services, Adolescent Ambulatory, Adolescent Ambulatory Unlocked, Non Residential Detox, Adult Residential with Child Care, Residential Transition Programs, 24 Hour residential Services/Duplexes Apartments, 24 Hour Community Residential Services Small Group Homes	Assisted Self Preservation ≤ 5
	SR-1.3	Personal Care: Residential treatment Homes, Adolescent Ambulatory, Adolescent Ambulatory Unlocked, Non Residential Detox, Adult Residential with Child Care, Residential Transition Programs	(Impractical) Assisted Self Preservation ≤ 5

- 5) **903.2.10 Piers or wharves and windowless stories in all occupancies.** An automatic sprinkler system shall be installed in the locations set forth in Sections 903.2.10.1 through ~~903.2.10.1.4~~ 903.2.10.1.3 and 903.2.10.4.

- 6) **[B] Group I-2.** This occupancy shall include buildings and structures used for medical, surgical, psychiatric, nursing, health or custodial care of persons who are not

capable of self-preservation. This group shall include, but not be limited to, the following:

- Hospitals (see definition for hospitals and mental hospitals).
- Nursing homes (see definition)
- Mental hospitals (see definition for hospitals and mental hospitals)
- Detoxification facilities (see definition)
- Ambulatory health care facilities (see definition)

~~A facility such as the above with five or fewer persons shall be classified as Group B.~~

Note: the remainder of the section to remain the same.

7) Page 47, Section 408.12 Group SR occupancies. Box references, OAR Chapter 411 -055 and OAR Chapter 411-056 have now been combined into OAR 411-054. Please make a note in your OFC and this will be updated when the new code is adopted in 2010.