

## CHAPTER 22

### MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES

**2201.2 Permits.** Permits shall be required as set forth in Section 105.6. **For plans requirements for aboveground tanks, see Section 3401.4.1.**

**2202.2.1 Limited application.** For the purpose of Chapter 22, certain terms are defined as follows:

**NON-RETAIL FACILITY.** Means an unattended or dual operations facility where Class I flammable liquids are dispensed through a card or key activated fuel-dispensing device by non-retail customers.

**RETAIL FACILITY.** Means a facility that sells Class I flammable liquids to the public in compliance with ORS 480.330.

**2204.2 (Not adopted) Attended self-service motor Fuel-dispensing facilities.** *Attended self-service motor fuel-dispensing facilities shall comply with Sections 2204.2.1 through 2204.2.5. Attended self-service motor fuel-dispensing facilities shall have at least one qualified attendant on duty while the facility is open for business. The attendant's primary function shall be to supervise, observe and control the dispensing of fuel. The attendant shall prevent the dispensing of fuel into containers that do not comply with Section 2204.4.1, control sources of ignition, give immediate attention to accidental spills or releases, and be prepared to use fire extinguishers.*

**2204.2.1 (Not adopted) Special-type dispensers.** *Approved special-dispensing devices and systems such as, but not limited to, card-or coin-operated and remote-preset types, are allowed at motor fuel-dispensing facilities provided there is at least one qualified attendant on duty while the facility is open to the public. Remote preset-type devices shall be set in the "off" position while not in use so that the dispenser cannot be activated without the knowledge of the attendant.*

**2204.2.2 (Not adopted) Emergency controls.** *Approved emergency controls shall be provided in accordance with Section 2203.2.*

**2204.2.3 (Not adopted) Operating instructions.** *Dispenser operating instructions shall be conspicuously posted in approved locations on every dispenser.*

**2204.2.4 (Not adopted) Obstructions to view.** *Dispensing devices shall be in clear view of the attendant at all times. Obstructions shall not be placed between the dispensing area and the attendant.*

**2204.2.5 (Not adopted) Communications.** *The attendant shall be able to communicate with persons in the dispensing area at all times. An approved method of communicating with the fire department shall be provided for the attendant.*

**2204.3 Non-retail dispensing facilities.** Non-retail dispensing facilities shall comply with Sections 2204.3.1 through 2204.3.7.

**2204.3.1 General.** When non-retail dispensing facilities **dispensing flammable liquids** are **permitted**, the owner or operator shall provide, and be accountable for, daily site visits, regular equipment inspection and maintenance.

**ORS 480.310 through 480.385 and OAR 837-020-0025 through OAR 837-020-0125 are not a part of this code but are reproduced or paraphrased here for the reader's convenience.**

**Self service gasoline dispensing at retail is prohibited in Oregon. However, non-retail commercial fueling is allowed, ORS 480.310 through 480.385 and OAR 837-020-0025 through 837-020-0125 are the State of Oregon administrative provisions pertaining to non-retail fueling sites including: definitions, operations, prohibitions, conditions of use, fire safety training, licensing, installations, certifications and record keeping, inspections and fees and penalties.**

**2204.3.2 Dispensers.** Dispensing devices shall comply with Section 2206.7.

**2204.3.7 Quantity limits.** Dispensing equipment used at unsupervised locations shall comply with one of the following:

1. Dispensing devices shall be programmed or set to limit uninterrupted fuel delivery to 25 gallons (95 L) and require a manual action to resume delivery.  
**Exception: Class II or IIIA liquids may be programmed or set to limit uninterrupted fuel delivery of up to 50 gallons (190 L).**
2. The amount of fuel being dispensed shall be limited in quantity by a preprogrammed card as approved.

**2205.4 Sources of ignition.** Smoking and open flames shall be prohibited **within 25 feet (7620 mm) of fueling operations.** The engines of vehicles being fueled shall be shut off during fueling. Electrical equipment shall be in accordance with the *ICC Electrical Code*.

**2206.2.3 Above-ground tanks located outside, above-grade.** Above-ground tanks shall not be used for the storage of Class I, II or IIIA liquid fuels except as provided by this section.

1. Above-ground tanks used for outside, above-grade storage of Class I liquids shall be listed and labeled as protected above-ground tanks **or, when approved by the fire code official, other above-ground tanks that comply** with Chapter 34. Such tanks shall be located in accordance with Table 2206.2.3.
2. Above-ground tanks used for above-grade storage of Class II or IIIA liquids are allowed to be protected above-ground tanks or, when approved by the fire code official, other above-ground tanks that comply with Chapter 34. Tank locations shall be in accordance with Table 2206.2.3.
3. **Protected** tanks containing fuels shall not exceed 12,000 gallons (45 420 L) in individual capacity or 48,000 gallons (181 680 L) in aggregate capacity. **Other tanks shall not exceed 6,000 gallons (22 712 L) in individual capacity or 18,000 gallons (68 137 L) in aggregate capacity.** Installations with the maximum allowable aggregate capacity shall be separated from other such installations by not less than 100 feet (30 480).  
**Exception: Tanks containing Class II or IIIA liquids may be of greater capacity when approved by the fire code official.**
4. Tanks located at farms, construction projects, or rural areas shall comply with Section 3406.2.

**Table 2206.2.3**

**TABLE 2206.2.3  
MINIMUM SEPARATION REQUIREMENTS FOR ABOVE-GROUND TANKS**

CLASS OF LIQUID AND TANK TYPE	INDIVIDUAL TANK CAPACITY (gallons)	MINIMUM DISTANCE FROM NEAREST IMPORTANT BUILDING ON SAME PROPERTY (feet)	MINIMUM DISTANCE FROM NEAREST FUEL DISPENSER (feet)	MINIMUM DISTANCE FROM LOT LINE WHICH IS ORGAN BE BUILT UPON, INCLUDING THE	MINIMUM DISTANCE FROM NEAREST SIDE OF ANY PUBLIC WAY (feet)	MINIMUM DISTANCE BETWEEN TANKS (feet)
Class I protected above-ground tanks or tanks in vaults	Less than or equal to 6,000	5	25"	15	5	3
	Greater than 6,000	15	25"	25	15	3
Class H and HI protected above-ground tanks or tanks in	Same as Class I	Same as Class I	Same as Class I	Same as Class I	Same as Class I	Same as Class I
Other tanks	All	50	50 <sup>a</sup>	100	50	3

For SI: 1 foot = 304.8 mm, 1 gallon = 3.785 L.

a. At fleet vehicle motor fuel-dispensing facilities, no minimum separation distance is required.

**2207.1 General.** Motor fuel-dispensing facilities for liquefied petroleum gas (LP-gas) fuel shall be in accordance with this section and Chapter 38. **Refer to ORS 480.410 through 480.490 and OAR 837-030-0100 through 837-030-0280 for administrative provisions pertaining to liquefied petroleum gas licensing and notification of liquefied petroleum gas installations.**

**ORS 480.410 through 480.490 and OAR 837-030-0100 through 837-030-0280 are not a part of this code but are reproduced or paraphrased here for the reader's convenience.**

**ORS 480.410 through 480.490 and OAR 837-030-0100 through 837-030-0280 are the State of Oregon administrative provisions pertaining to liquefied petroleum gas including: definitions, fire and life safety standards, licensing, installations, examinations and fees and penalties.**

**2208.6.1 Emergency breakaway devices.** Dispenser hoses for compressed natural gas dispensing systems for containers or vehicle resale shall be equipped with a listed emergency breakaway device designed to retain liquid on both sides of a breakaway point. Such devices shall be installed and maintained in accordance with the manufacturer's instructions.

**2208.7 Emergency shutdown device.** An emergency shutdown device shall be located within **100 feet (30 480 mm)** of, but not less than **20 feet ( 6096 mm)** from, dispensers, and shall also be provided in the compressor area. Upon activation, the emergency shutdown shall automatically shut off the power supply to the compressor and close valves between the main gas supply and the compressor and between the storage containers and dispensers.

**2210.6.1 Standpipes and hose stations.** Piers, wharves and floats at marine motor vehicle fuel-dispensing stations with any portion in excess of **250 feet (76 200 mm)** from fire apparatus access shall be equipped with an approved wet standpipe system installed in accordance with Chapter 9.

**Exception:** Waterlines shall normally be dry where subject to freezing temperatures.

Fire hose, where provided, shall be enclosed within a cabinet, and hose stations shall be labeled: FIRE HOSE-EMERGENCY USE ONLY.

**2210.6.1.1 Water supply. Piers and wharves shall be provided with water supply systems. Water supply systems shall be in the form of on-site fire hydrants or as required by the fire code official.**

**2210.6.1.2 Sprinkler systems. Piers and wharves shall be installed with an automatic sprinkler system when required by the *International Building Code*.**